

Siemens Building Technologies Ltd., CH-8708 Männedorf

Siemens Nederland BV
Siemens Building Technologies
Dhr Erdal Buke
Postbus 16068
NL-2500 BB Den Haag

Name	Dr. Horst Dittrich
Department	C-IPR
Phone	+41 1 922 66 72
Fax	+41 1 922 69 69
E-Mail	horst.dittrich@siemens.com
Your letter dated	-
Our ref.	Dih
Date	24. October 2002

Declaration of Conformity for BC10

The undersigned persons who are authorized to execute the present Declaration confirm that the fire control and indicating equipment units types BC1002/04 and BC1008/12 meet the requirements of the following standards and guidelines:

- EN 54, Part 2 (12/1997), Control and Indicating Equipment, Sect. 4 -15
- EN 54, Part 4 (12/1997), Power Supply Equipment, Sect. 5 - 9.15
- VdS 2540, (12/1996) Guidelines for Fire Detection Systems, Control and Indicating Equipment, Requirements and Test Methods, Sect. 5
- VdS 2541, (12/1996) Guidelines for Fire Detection Systems, Power Supply Equipment, Requirements and Test Methods, Sections 4.3 and 5.

Siemens Building Technologies AG
Fire & Security Products



Dr. Alfred Wüthrich
Head of Product Line Fire



Dr. Horst Dittrich
Patent Counsel C-IPR

Siemens Building Technologies AG

Fire & Security Products
Alte Landstrasse 411
CH-8708 Männedorf

Phone +41 1-922 61 11
Fax +41 1-922 64 50
www.cerberus.ch

Vortage

2 Test purpose and basis

Type testing of the control and indicating equipment units types BC1002/04 and/or BC1008/12 is to ascertain compliance with the requirements of the following standards and VdS Guidelines for Alarm Signalling Systems.

All test results refer exclusively to the test item described under Chapter 1.

- EN 54, Part 2 (12/1997), Control and Indicating Equipment, Sect. 4 - 15
- EN 54, Part 4 (12/1997), Power Supply Equipment, Sect. 5 - 9.15
- VdS 2540, (12/1996) Guidelines for Fire Detection Systems, Control and Indicating equipment, Requirements and Test Methods Sect. 5
- VdS 2541, (12/1996) Guidelines for Fire Detection Systems, Power Supply Equipment, Requirements and Test Methods Sections 4.3 and 5

All test results contained in this Test Report refer exclusively to the items subjected to the test.

The following options with requirements according to DIN EN 54-2 have been chosen by the manufacturer and were incorporated in the control and indicating equipment.

- 7.8 Output for the triggering of alarming devices
- 7.11 Routing delay
- 7.12 Two detector coincidence
- 8.3 Fault signals of detection points
- 8.9 Fault signal routing to transmission devices
- 10.1 Test condition, general requirements
- 10.2 Indication of the test condition
- 10.3 Indication of detector zones under test conditions

5 Overall test result

The fire control and indicating equipment type BC 1002/04 with integrated power supply (24V/0,7A) and/or BC 1008/12 with integrated power supply (24V/1,5A) meet the requirements of the standards and guidelines specified under Item 2.